



PLANNING DEVELOPMENT REVIEW DEPARTMENT

505 Barton Springs Road
Austin, TX 78704

REQUEST FOR MODIFICATION OR ALTERNATE METHOD OF COMPLIANCE

Address:			Use:		Type of Const:	
Suite #:	Building #:	# of Stories:	Sprinkled YES <input type="checkbox"/> NO <input type="checkbox"/>		Total Sq. Feet of Building:	Sq. Ft. of Project:
Name of Building:		Date:	Permit:		Contact Person:	
BUILDING OWNER:			MAILING ADDRESS:			
			E-mail Address:			
Check One →	<input checked="" type="checkbox"/> Building	<input type="checkbox"/> Electrical	<input type="checkbox"/> Mechanical	<input type="checkbox"/> Plumbing	<input type="checkbox"/> Energy	<input type="checkbox"/> Fire

Requesting an alternate method of compliance to the 2015 IRC table R302.1(2) foot notes a & b which states:

- a. Roof eave fire-resistance rating shall be permitted to be reduced to 0 hours on the underside of the eave if fireblocking is provided from the wall top plate to the underside of the roof sheathing.
- b. Roof eave fire-resistance rating shall be permitted to be reduced to 0 hours on the underside of the eave provided that gable vent openings are not installed

Fireblocking blocking materials as per R302.11.1

EVALUATION **FIRE DEPARTMENT CONCURENCE REQUIRED**

APPROVED BY: TITLE: Deputy Building Official DATE: 7-18-2014

APPROVED BY: TITLE: Residential Inspections Supervisor DATE: 7-18-2014

APPROVED BY: TITLE: Program Manager DATE: 7-18-2014